

**A meeting was held on 21-02-2017 in the chairmanship of Principal Secretary, UD&HD for PowerPoint Presentation on Bhagalpur Water Supply Phase-II.**

Following persons were present in the meeting.

- 1) Sri, Chaitanya Prasad (IAS) Principal Secretary UD&HD
- 2) Sri, N. K. Singh (IAS) <sup>Bala</sup> Special Secretary UD&HD
- 3) Sri, A. P. Singh (IAS), Managing Director, BUIDCo
- 4) Sri, A. K. Jha, Assistant Director UD&HD
- 5) Sri, Birendra Kumar, APD- ADB Project
- 6) Sri, P.N.Singh, EE-PMU
- 7) Sri, Rajkishore SO, UD&HD
- 8) Sri, K.S.Rathore, Consultant ADB
- 9) Sri, A. Hussain, DTL-PMC
- 10) Sri, T.K. Raghunathan ATL-DSC
- 11) Sri, Bala, Assistant Engineer Design-DSC


Following decision were taken in the meeting: -

- 1) It was decided that the concept design of Intake well/ Jack well and water treatment plant shall be vetted by IIT-Roorkee. The DSC shall get it done on topmost priority within a period of three weeks.
- 2) The Operation & Maintenance period shall be kept for a period of ten years. Accordingly the cost may be revised.
- 3) The provision shall be incorporated in the Bid Document that the design submitted by the DBO contractor for Intake/ Jack well & WTP shall be vetted by a third party as decided by the Employer before approval by the Engineer.
- 4) It was decided that the SCADA system should also incorporate each & every branch line coming out from OHT.
- 5) It was observed that there is a need of synchronization for construction of various components under BWSP-1 & BWSP-2, so that assets created under BWSP-1 should be in a position to be put to use by supply of water for that particular area. It was decided that DSC should submit a synchronization plan of construction activities of both BWSP-I and BWSP-II within a period of fifteen days. Accordingly DSC should prepare an overall plan of BWSP-I and BWSP-II and be submitted within two weeks.

P:1/2

*R. Kumar*


- 6) PMC Environment Expert shall clarify as per the E/A notification whether EC from the department of Environment & Forest is required or not.
- 7) It is decided that the DSC after incorporating above positions, should submit the revised bidding documents particularly section 6, civil specification & Technical specification within a maximum period of one month.
- 8) A provision regarding evaluation purposes of the bids, the net present value (NPV) should be calculated with a discount rate of 10 %.
- 9) However the process for procurement, bidding document will continue as it is, as per agreed procurement plan during the ADB Mission dated 15-21 December 2016. In case of some changes due to above decision, it will be incorporated in the bidding document before issuing of invitation of bid (IFB)

  
27/3/2017  
Principal Secretary,  
UD&HD, Patna

Memo No. 810

Date: 29/3/17

Copy to:- All concern person for information and necessary action.

  
27/3/2017  
Principal Secretary,  
UD&HD, Patna



